

User Manual for **K7** Indicator




VALUE EACH GRAM
HiWEIGH

Part 1


UNBOXING

After the weighing indicator received, please open the box carefully and check the following items included:


Standard:



Power Adapter



RS232
Data Serial Port



Load Cell Connector

Key Functions



Switch On/Off

Print

Weight Unit Exchange/ User Function Set

Zero

Tare

Accumulate and Print

LCD Display



Part 2

STANDARD OPERATION

1. Switch On/Off

Press  key to turn on the indicator

Press  key to turn off the indicator

2. Zero

If the indicator not on zero point and the weight value $< 2\%F.S.$, press  key to zero the scale, and the  ZERO arrow will display.

3. Tare

3.1 Manual Tare:

Put the container on the scale (weight > 0) and after the read stable (also the tare arrow not appear), press  the scale will remove the weight read and record as tare, and the scale will display the net weight, press  again, it will display the gross weight (tare + net weight).

3.2 Repeat Tare:

After the first tare operation, put the 2nd weight on the scale, press  , it will display the gross weight of 1st+2nd weight and press  again, it will take that gross weight as new tare weight and start the new net weighing operation.

3.3 Remove Tare:

When the net weight display and the tare arrow appears, press  , it will remove the tare value and display the gross weight, and the  NET disappears.

3.4 Auto Tare:

When the user function (AUT) set to be 10 or 11 and the weight reach to the valve value as it set, the scale will do tare automatically, refer to AUT configuration.

4. Print

In manual print/accumulate mode, when the weight value >20d and stable, press , it will print the weight bill, and it can be printed once again if you press  again.



5. Accumulate and Print



In manual print/accumulate mode, when the weight value >20d and stable, press , it will print the weight receipt and accumulate to the record (also it will display the accumulation times like [n 12]), next print/accumulating available only after the weight value <20d.

6. Weight Unit Exchange/ User Function Set


Long press  key for 2 seconds to exchange between the 1st unit and 2nd unit. Kg and lb, g and oz, t only. Enter function during parameter configuration.


7. Accumulated Record Retrieve and Clean (In weighing mode)

Operation	Display	Explanation
Long press 	[n 12] 	Display accumulated times
Press 	[H 3] 	Display the first 4 digits

Operation	Display	Explanation
Press 	[L506.5] 	Display the following 4 digits, accumulated weight=3506.5
Press 	[n 12] 	When it displays the accumulated times, press to clean the accumulated record
Press 	[0] 	Return to weighing mode



8. User Setting Menu

Operation	Display	Explanation
Press 	[Aut 00] 	Weighing mode set
Press 	[000200] 	Auto tare valve value (when Aut=10 or 11)



Operation	Display	Explanation
Press 	<p>[PrInt]</p> 	Communication, printing format and percentage set
Press 	<p>[PERC]</p> 	Set weight value for percentage weighing (100%)
Press 	<p>[SEtP]</p> 	Set setpoints
Press 	<p>[PCS]</p> 	Set sample quantity (Aut=07)
Press 	<p>[0.002]</p> 	10 times resolution
Press 	<p>[0.00]</p> 	Return to weighing mode



9. Weighing Mode Set





Operation	Display	Explanation
Press 	[Aut 00] 	User function set
Press  Press  or  Press 	[Aut 01] 	<p>00: Normal weighing mode, manual print/accumulate</p> <p>01: Normal weighing mode, automatic print/accumulate after the weight stable, auto arrow appears</p> <p>02: Normal weighing mode, automatic save the weight value, and print/accumulate it after the load < 20d and auto arrow appears</p> <p>03: Dynamic weighing mode, automatic print/accumulate after the weight <20d, auto arrow appears</p> <p>04: Peak hold mode, automatic print/accumulate after the weight <20d, auto arrow appears</p> <p>05: Dynamic weighing mode, manual print/accumulate</p> <p>06: Peak hold mode, manual print/accumulate</p> <p>07: Counting mode, manual print/accumulate</p>



Operation	Display	Explanation
		<p>08: Positive/Negative weighing, use for testing the tension or compression force</p> <p>09: Minus weighing mode</p> <p>10: Automatic tare mode</p> <p>11: Continuous automatic tare mode.</p> <p>Modify the mode and push FN <small>UNIT</small> to confirm</p>
<p>Press FN <small>UNIT</small></p> <p>Press +T+ or -0- <small>↑%</small> <small>↓</small></p> <p>to modify</p>	<p>[Aut 03]</p>  <p>[t 3]</p> 	<p>If the Aut=03 or 05, there is the time set for dynamic weighing (average weight during the set time).After set done, press FN <small>UNIT</small> to confirm.</p>
<p>Press FN <small>UNIT</small></p>	<p>[0]</p> 	<p>Return to weighing mode</p>

10. Communication | Print Configuration



Operation	Display	Explanation
Press 	[Aut 00] 	Weighing mode selection
Press 	[PrInt] 	Communication, printing set
Press  ↓ Press  or  ↑ Press 	[Adr 00] 	Communication address selection
Press  ↓ Press  or  ↑ Press 	[b1 24] 	COM1 baud rate select: 24=2400 48=4800 96=9600 144=14400 192=19200
Press  ↓ Press  or  ↑ Press 	[CHE1 n] 	COM1 Check mode n: None E: Even check O: Odd check S: Always 0 A: Always 1

Operation	Display	Explanation
Press  → Press  or  ↕ Press  <small>UNIT</small>	[C1 Ct1] 	COM1 Output Ct1: Continuous output Cnd: Command (Modbus) F1: Print format 1 F2: Print format 2 F3: Print format 3 Ct2: Stable output(when Aut=01) Ct3: Continuous output (format = Ct2)
Press  → Press  or  ↕ Press  <small>UNIT</small>	[b2 24] 	COM2 baud rate select: 24=2400 48=4800 96=9600 144=14400 192=19200
Press  → Press  or  ↕ Press  <small>UNIT</small>	[CHE2 n] 	COM2 Check mode n: None E: Even check O: Odd check S: Always 0 A: Always 1
Press  → Press  or  ↕ Press  <small>UNIT</small>	[C2 Ct1] 	COM1 Output Ct1: Continuous output Cnd: Command (Modbus) F1: Print format 1 F2: Print format 2 Ct2: Stable output(when Aut=01) Ct3: Continuous output (format = Ct2)

Operation	Display	Explanation
Press  → Press  or  ↓ Press 	[dF 2] 	Date format 0 = d/m/y 1 = m/d/y 2 = y/m/d
Press  → Press  or  ↓ Press 	[tlt 2] 	Printing head 0: None 144=14400 192=19200 1: On top 2: On bottom 3: Both (top and bottom)
Press  or  ↓ Press  → Press  or  to next letter Press  to end	[00~077]  [01~079]  [25~255] 	Top head input (total 64 letters): 00: The sequence of letter 087: ASCII code, 087 represents M, 079 represents O... (refer to appendix I) and input 255 to end the head

Operation	Display	Explanation
<p>Press  or </p> <p>Press </p> <p>Press  or </p> <p>to next letter</p> <p>Press  to end</p>	<p>[00~077]</p>  <p>[01~079]</p>  <p>....</p> <p>[25~255]</p> 	<p>Bottom head input (total 64 letters):</p> <p>00: The sequence of letter</p> <p>087: ASCII code, 087 represents M, 079 represents O... (refer to appendix I) and input 255 to end the head</p>
	<p>[0.0]</p> 	<p>Configuration saved and back to weighing mode</p>



11. Percentage Weighing


Operation	Display	Explanation
Press  <small>UNIT</small>	[Aut 00] 	Weighing mode selection
Press  <small>UNIT</small>	[PrInt] 	Communication, printing format and percentage set
Press  <small>UNIT</small>	[PERC] 	Set weight value for percentage weighing (100%)
Press  ↓ Press  or  ↓ Press  <small>UNIT</small>	[3000] 	Input the weight value for 100% index
Press  <small>UNIT</small>	[0.0] 	Back to the weighing mode




Note: Percentage weighing available only when Aut=00, and long press  for 2 seconds to start the percentage weighing mode.


12. Setpoints

For instructions on setpoints, please refer to **20.Setpoint Output**

Operation	Display	Explanation
Press 	[Aut 00] 	Weighing mode selection
Press 	[PrInt] 	Communication, printing format and percentage set
Press 	[PERC] 	Set weight value for percentage weighing (100%)
Press 	[SETP] 	Set setpoints
Press  → Press  or  ↕ Press 	[oP 0] 	Setpoints mode: oP=0: no output oP=1: 2 setpoints output oP=2: 4 setpoints output (for 3-LED alarming lights) oP=3: 4 setpoints output

Operation	Display	Explanation
Press 	[r00050] 	When the fixed output starts weighing, the fixed output does not work.
Press  ↓ Press  or  ↑ ↓ Press 	[ALA 0] 	Beeper working mode: ALA=0: No beep ALA=1: It beeps when the weight out of range (Hi/Low, stable) ALA=2: It beeps when the weight within range (OK, stable)
Press  ↓ Press  or  ↑ ↓ Press 	[A00500]  [000000]  [000200] 	A setpoint input


Operation	Display	Explanation
<p>Press </p> <p>→</p> <p>Press  or </p> <p>↕</p> <p>Press </p>	<p>[b00700]</p>  <p>[000000]</p>  <p>[000300]</p> 	<p>B setpoint input</p>
<p>Press </p> <p>→</p> <p>Press  or </p> <p>↕</p> <p>Press </p>	<p>[C00100]</p>  <p>[000000]</p>  <p>[000400]</p> 	<p>C setpoint input</p>



Operation	Display	Explanation
Press  ↓ Press  or  ↑ ↓ Press 	<p>[D01200]</p>  <p>[000000]</p>  <p>[000500]</p> 	D setpoint input
	<p>[0.0]</p> 	

13. Counting

13.1 Sampling

Put the sample on the scale (if the scale is not zero, please zero or tare the scale firstly) and it's more precise if there are more samples counted (1-999)





Operation	Display	Explanation
Put the sample on the scale	[26.0] 	Display the weight of the sample
Press  Press  Press  or 	[Aut 00]  [Aut 07] 	Select Aut=07 (counting mode)
Press 	[PrInt] 	Communication and printing set
Press 	[PErC] 	Set weight value for percentage weighing (100%)

Operation	Display	Explanation
Press 	[SETP] 	Set setpoints
Press 	[PCS] 	Set the number of sample, this menu appears when Aut=07
Press  Press  or 	[Cnt000]  [Cnt030] 	Input the sample number Example = 30
Press 	[C 30] 	Save the sample number Ready for counting operation

13.2 Counting

After sampling saved, put the goods on the scale, it will display the quantity of the goods, like [C 108], press  to shift the display between the quantity or the weight of the goods, and after the weight stable, press  to print the receipt or accumulated receipt. (Requires to set output in print format)

13.3 Counting Records and Clean

Operation	Display	Explanation
	<p>[C 108]</p> 	In counting mode
Long press 	<p>[n 8]</p> 	Display the accumulated times
Press 	<p>[C 532]</p> 	Display the total quantity
Press 	<p>[C 108]</p> 	Back to counting mode
Press 	<p>[n 8]</p> 	When it displays the accumulated times, press  to clean the accumulated value and back to counting mode

14. Positive/Negative Weighing

{Aut=08}

In this mode, the indicator can accept the positive or negative signal, when it displays the positive weight, tare operation is available, when it displays the negative weight, the tare operation can't access. Accumulating and printing is unavailable for this mode.

15. Minus Weighing

{Aut=09}

In this mode, the indicator will display the removed load.

Put the object on the scale, long press  to zero the scale, now remove the object and the scale will display the removed weight. Tare/Accumulate/Print is available for this mode.

16. Automatic Tare

After Aut=10 or 11 configured, press , it will display the valve value [000200], set the value by  or  or , if the decimal point set as 0.0, the [000200]=20.0

{Aut=10} Auto Tare

In this mode, when the weight > the valve value, it will do tare automatically.

When the scale back to zero (empty), it will clean the tare automatically.



{Aut=11} Continuous Auto Tare

In this mode, when the weight > the valve value, it will do tare automatically, and now put more objects on the scale, and after the weight stable, press  or  to print or accumulated print, the scale will do tare again by itself.






When the scale back to zero (empty), it will clean the tare automatically.



17.Clock Adjust

When it display time or date, press  to shift display of time or date.

Operation	Display	Explanation
	<p>[27]</p> 	In weighing mode
<p>Long press </p> <p>Press  →</p> <p>Press  or </p>	<p>[00:00:80]</p>  <p>[09:30:01]</p> 	<p>Display time (hour/minute/second)</p> <p>After modifying, press  to confirm</p>
<p>Press </p> <p>Press  →</p> <p>Press  or </p>	<p>[00.01.01]</p> 	<p>Press  to display the date</p> <p>After modifying, press  to confirm</p>
<p>Press </p>	<p>[0.0]</p> 	Back to the weighing mode

18.Weight Record Retrieve and Print

Operation	Display	Explanation
	<p>[27]</p> 	In weighing mode
<p>Long press </p>	<p>[n 8]</p> 	Display the accumulated times
<p>Press </p> <p>Press  or </p>	<p>[000008]</p> 	Input the serial number of the weight record
<p>Press </p>	<p>[r 2]</p> 	Display the sequence number of that record
<p>Press </p> <p>Press </p>	<p>[r 3]</p>  <p>[r 2]</p> 	<p>Display the next record</p> <p>Display the previous record</p>

Operation	Display	Explanation
Press 	[16.06.03] 	Display the date of that record
Press 	[14:53:02] 	Display the time of that record
Press 	[30.06] 	Display the gross weight of that record
Press 	[20.00] 	Display the tare weight of that record
Press 	[10.06] 	Display the net weight of that record
Press 	[153] 	Display the quantity of that record (for counting)

Operation	Display	Explanation
Press 	[27.00] 	Push  to return to weighing mode during any data display (date-time-gross weight-tare weight-net weight-quantity)
Press 	[16.06.03] 	Press  to print the record during any data display (Requires to set output in print format)
Press  Press  or 	[b 0001] 	Press  to input the start number of the records (for retrieve)
Press 		
Press  Press  or 	[E 0008] 	Input the end number of the records (for retrieve)
Press 	[27.00] 	It will print all records from 0001 to 0008 and back to weighing mode after the printing ends. (Requires to set output in print format)

19.Communication Protocol

Byte format: 8 bits; if there is check bit, it's the first digit; one stop bit

Output format:

19.1 Continuous format (Ct1, Ct2, Ct3): if the display weight = -123.45

Ct1: no matter the weight stable or not, output continuously:

Adr=00-98: =54.3210=54.3210=54.3210-...

Adr=99: =-0123.45=-0123.45=-0123.45...

Ct2: When the weight stable, output the following ASCII code:

A B CCCCC D EE F G

02, 2D, 30, 31, 32, 33, 2E, 34, 35, 20, 6B, 67, 47, 0D

A	B	C	D	E	F	G
Start 0x02	Sign >=0, 0x20	Weight include decimal point	Space 0x20	Unit kg/lb/t	G/N	Enter 0x0D

Ct3: No matter the weight stable or not, continuous output the Ct2 data.

19.2 Command (Cnd)

COM1: Modbus

COM2: Handshaking, the computer send the request (ASCII) as below:

P – print gross/tare/net weight

G – Print gross weight

B – Print tare weight

N – print net weight

A – Print quantity

Z – Zero

T- Tare

C – Clean tare

19.3 Print format (F1)

Weighing Bill	Counting Bill (Aut=07)
HIWEIGH TECHNOLOGIES 03-06-2017 14:58:26 No.0002 G: 7.73kg T: 4.82kg N: 2.91kg	HIWEIGH TECHNOLOGIES 03-06-2017 14:58:26 No.0002 G: 7.73kg T: 4.82kg C: 54pcs

19.4 Print format (F2)

Weighing Bill	Counting Bill (Aut=07)
No.0002 03-06-2017 14:58:26 7.73kg	No.0002 03-06-2017 14:58:26 7.73kg 54pcs

19.5 Print format (F3)

Weighing Bill
0002 03-06-2017 14:58:26 7.73kg 4.82kg 2.91kg
Counting Bill (Aut=07)
0002 03-06-2017 14:58:26 7.73kg 4.82kg 2.91kg 54pcs

19.6 Accumulated format

Weighing Bill	Counting Bill (Aut=07)
03-06-2017 14:58:26 No.0002 S: 25.02kg	03-06-2017 14:58:26 No.0002 C: 108pcs S: 25.02kg

19.7 Countinous ouput (Ct4)

Send continuously regardless of stability. If the screen shows 12.34kg, send: ST,+00012.34kg

19.8 Manually output (FC1)

Press  to send, the format is the same as CT1

19.9 Manually output (FC3)

Press  to send, the format is the same as CT2

19.10 Manually output (FC4)

Press  to send, the format is the same as CT4

19.11 Countinous ouput (Ct5)

Send continuously regardless of stability, the format is the same as Fox's Ct1

20.Setpoints Output

A B C D 4 setpoints, $A < B < C < D$

Relay board optional, not included in standard package

24.1oP=1 (2 relay output 1# and 2#)

$W < A$ or $W > D$: Hi/Ok/Lo LED lights off and no relay output

$A \sim W \sim B$: Lo LED on, 1# relay output

$B < W < C$: OK LED on, no relay output

$C \sim W \sim D$: Hi LED on, 2# relay output

Relay connecting (sharing with RS232C DB9 interface):

Pin6 & pin7: 1# relay NO (normally open)

Pin8 & pin9: 2# relay NO (normally open)

24.2oP=2 (4 relay output 1#, 2#, 3# and 4#)

If connecting to the 3-LED alarming lights:

1# - yellow, 2# - green, 3# - red, 4# - beeper

$W < A$: Lo LED lights on, 1# and 4# relay output

$A \sim W < B$: Lo LED on, 1# relay output

$B \sim W \sim C$: OK LED on, 2# relay output

$C < W \sim D$: Hi LED on, 3# relay output

$W > D$: Hi LED on, 3# and 4# relay output

Relay connecting (sharing with RS232C DB9 interface):

Pin1: COM

Pin6: 1# relay NO (normally open) Pin8: 3# relay NO (normally open)

Pin7: 2# relay NO (normally open) Pin9: 4# relay NO (normally open)

24.3oP=3 (4 relay output 1#, 2#, 3# and 4#)

$W \sim A$: Lo LED lights on, 1# and 2# relay output $W \geq C$: Hi LED on, 3# relay output

$W \sim B$: Lo LED on, 2# relay output $W \geq D$: Hi LED on, 3# and 4# relay output

$B \sim W \sim C$: OK LED on

Relay connecting (sharing with RS232C DB9 interface):

Pin1: COM

Pin6: 1# relay NO (normally open)

Pin8: 3# relay NO (normally open)

Pin7: 2# relay NO (normally open)

Pin9: 4# relay NO (normally open)

VALUE EACH GRAM
HiWEIGH